



**LEGAL NOTICE OF INTENT TO ISSUE STANDARD AIR
CONTAMINANT DISCHARGE
PERMIT NO. 202537 (ACDP 202537)**

In accordance with Title 37 of Lane Regional Air Protection Agency's Rules and Regulations, the following facility has made application for a Standard Air Contaminant Discharge Permit.

**Metropolitan Wastewater Management Commission –
Eugene/Springfield Water Pollution Control Facility (Modification)
Sewage Treatment Facility Employing Internal Combustion Engines for
Electrical Power Generation
410 River Avenue, Eugene**

Emissions will be limited by the permit to:

NOx = 98 tons per year; CO = 99 tons per year;
 VOC = 46 tons per year; GHG = 74,000 tons per year;
 Single HAP = 9 tons per year; Total HAPs = 24 tons per year.

None of these emission limits will result in an increase over the netting basis that exceeds the Significant Emission Rate (SER) established by Lane Regional Air Protection Agency (LRAPA).

The following table presents maximum allowable emissions of criteria pollutants for the facility. The current emission limit reflects maximum emissions the facility can emit under the existing permit. The proposed emission limit reflects maximum emissions the facility would be able to emit under the proposed permit. Typically, a facility's actual emissions are less than the maximum limits established in a permit; however, actual emissions can increase up to the permitted limit.

Criteria Pollutant	Current Limit (tons/year)	Proposed Limit (tons/year)
Particulate matter	NA	NA
Coarse particulate matter (PM ₁₀)	NA	NA
Fine particulate matter (PM _{2.5})	NA	NA
Carbon monoxide	99	99
Nitrogen oxides	98	98
Sulfur dioxide	NA	NA
Volatile organic compounds	46	46
Greenhouse gases	74,000	74,000

For more information about criteria pollutants, go to EPA's "[Criteria Air Pollutants](#)" page.

LRAPA has prepared and proposes to issue a permit to this company. The Draft Permit and Review report are located for review on the LRAPA website at www.lrapa.org.

Anyone desiring to submit information concerning the application or proposed permit which might assist LRAPA in concluding the issuance of a permit for the above-listed company is urged to do so. Any comments must be submitted by **5:00 p.m. on:**

JUNE 28, 2021

Address comments to:

Written:

Lane Regional Air Protection Agency
1010 Main Street
Springfield, Oregon 97477

Attention: Permit Program

E-mail: permitting@lrapa.org